## WAC 296-45-901 (Cont.)

Table 4: DC Live Work Minimum Approach Distance With Transient Overvoltage Factor

| Maximum anticipated<br>Per-unit transient<br>Overvoltage | Distance to employee in feet-inches, conductor to ground  Air and clear live -line tool  Maximum phase-to-phase voltage in kilovolts |     |      |      |      |              |     |     |     |     |       |
|--|--|-----|------|------|------|--------------|-----|-----|-----|-----|-------|
|  |  |     |      |      |      |              | 250 | 400 | 500 | 600 | 750   |
|  |  |     |      |      |      | 1.5 or lower | 3-8 | 5-3 | 6-9 | 8-7 | 11-10 |
| 1.6  | 3-10   | 5-7 | 7-4  | 9-5  | 13-1 |              |     |     |     |     |       |
| 1.7  | 4-1  | 6-0 | 7-11 | 10-3 | 14-4 |              |     |     |     |     |       |
| 1.8  | 4-3  | 6-5 | 8-7  | 11-2 | 15-9 |              |     |     |     |     |       |

Note 1: The distances specified in this table may be applied only where the maximum anticipated per-unit transient overvoltage has been determined by engineering analysis and has been supplied by the employer. However, if the transient overvoltage factor is not known, a factor of 1.8 shall be assumed.

Note 2: The distances specified in this table are the air, and live-line tool distances.